

## Reconfiguration of the radial distribution network using an artificial rabbits optimization approach

Ganney Poorna Chandra Rao<sup>1</sup>, Puvvula Venkata Rama Krishna<sup>2</sup>, Mailugundla Rupesh<sup>3</sup>, Swathi Karike<sup>4</sup>, Sathyanarayana Polisetty<sup>5</sup>, Sareddy Venkata Rami Reddy<sup>6</sup>, Jadapalli Sreedhar<sup>1</sup>

<sup>1</sup>Department of Electrical and Electronics Engineering, Vignana Bharathi Institute of Technology, Hyderabad, India

<sup>2</sup>Department of Electrical Electronics and Communication Engineering, GITAM (Deemed to be University), Hyderabad, India

<sup>3</sup>Department of Electrical and Electronics Engineering, BVRIT HYDERABAD College of Engineering for Women, Hyderabad, India

<sup>4</sup>Department of Electrical and Electronics Engineering, Nalla Narasimha Reddy Education Society's Group of Institutions, Hyderabad, India

<sup>5</sup>Department of Electrical and Electronics Engineering, Sreenidhi Institute of Science and Technology, Hyderabad, India

<sup>6</sup>Department of Electrical and Electronics Engineering, JNTUA College of Engineering, Pulivendula, India

### Article Info

#### Article history:

Received Jul 26, 2023

Revised Jun 11, 2024

Accepted Jun 26, 2024

#### Keywords:

Artificial rabbits optimization

Radial distribution network

Reconfiguration

Sectionalizing switches

Tie switches

### ABSTRACT

Lowering system power losses along with improving voltage profile have been major concerns for researchers for the past few decades. The performance of an electrical distribution system (EDS) is dependent on these two factors. This work's main emphasis is on reconfiguring the radial distribution network (RDN) to diminish system power losses and strengthen the voltage profile. The process of network reconfiguration (NR) involves state transitions of sectionalizing and tie switches while still adhering to the limitations. In this work, the optimal reconfiguration network is determined using the artificial rabbits optimization (ARO) approach. The adopted method is tested using IEEE 119 bus RDN under low, normal, and heavy load conditions. When compared to the current approaches, the adopted methodology produced favorable results.

This is an open access article under the [CC BY-SA](#) license.



### Corresponding Author:

Ganney Poorna Chandra Rao

Department of Electrical and Electronics Engineering, Vignana Bharathi Institute of Technology  
Hyderabad, India

Email: g.poornachandrarao@gmail.com

## 1. INTRODUCTION

When an electrical distribution system (EDS) fails, network reconfiguration (NR) is performed to reduce the number of de-energised zones while preserving the maximum reliability of the system by operating switching devices remotely or automatically. The techniques did not prioritise power loss reduction through reconfiguration and distributed generation (DG) allocation [1], [2]. The goal of NR with DG is to reduce power losses by optimising network architecture, DG placement, and capacity [3], [4]. NR may be conceptualised as a mixed-integer nonlinear optimising problem, where continuous variables indicate the quantity of electrical power flowing via the system's branches and integer variables reflect the switches current positions [5]–[7]. EDS are evolving rapidly towards active distribution systems in order to improve reliability and standard of service through NR [8], [9]. However, the load demand uncertainties were not considered in [8]. The numerous benefits of NR include mitigated power loss, superior voltage quality, greater distribution of loads, and increased reliability. Simultaneous reconfiguration and DG allocation to reduce power losses were not given top priority in the techniques [10], [11]. The challenge related to service resumption is replicated as a complex programme. The goals are to maximise loads restored while

minimising switch operations, while also fulfilling grid operating restrictions and ensuring a radial operation configuration. The uncertainties in load and renewable DGs are not considered in [12], [13].

Managing energy is critical in EDS. An incorrect setting results in higher power loss and low voltage. The EDS should be redesigned in the future to have reduced power loss and higher voltage levels. The proposed methods were evaluated on IEEE 33 radial distribution network (RDN) only [14], [15]. Timely variable load demand complicates distribution network management and control, particularly in high load density zones. A distribution network's power loss will not be minimal with fluctuating load demand for a given network architecture [16], [17]. Concurrent network setup and DG installation in the EDS might diminish true power loss and advance the voltage characteristics. However, these methods did not consider NR at different load levels [18], [19]. NR at constant and variable loads is carried out to improve the efficacy of the EDS. The proposed technique is evaluated only on IEEE 33 RDN [20]. The high-voltage transmission system in a power supply transports the generated electricity to the distribution side's low-voltage users. I<sup>2</sup>R loss in a distribution system is considerably higher in comparison to a transmission system [21], [22]. Power system resilience is the capacity of the network to reduce the detrimental effects of rare, unfavorable events. A successful strategy to improve system resilience is to create microgrids with DGs to restore key loads in the distribution system when a significant outage occurs [23]. Real power losses in the EDS are significant, and bus voltages are lower. Optimal capacitor placement and NR strategies are two of the most cost-effective ways to increase voltage profiles and reduce losses while adhering to EDS restrictions [24], [25]. The need for multi-objective NR considering changes in load and DG has grown significantly; this is crucial and necessary to ensure network activities are both secure and effective [26], [27].

The methods used in the previous references take a lot of time, have a low convergence rate, and have a small search space. The recently created meta-heuristic algorithm artificial rabbits optimization (ARO) addresses prior algorithms poor convergence efficiency and limited search capabilities. The ARO algorithm was motivated by the need for rabbits to survive. The algorithm works well and is simple to use. ARO is used in this work with the objectives: i) to obtain an optimally reconfigured network in an IEEE 119 bus RDN, ii) to diminish the true power losses, and iii) to elevate the voltage pattern.

The present study is structured as follows: section 2 formulates the study's problem, the mathematical equations for the suggested method are defined in section 3, and the result evaluation and comparison are shown in section 4. Finally, the research's conclusion is presented in section 5.

## 2. PROBLEM IDENTIFICATION

ARO is used on an IEEE 119 bus RDN for obtaining an optimally reconfigured network with the least true power losses. Additionally, by diminishing the losses, the voltage levels are improved. The adopted method has an objective function given by (1). Minimization of loss given by:

$$f = \sum_{A=1}^n R_A \frac{P_A^2 + Q_A^2}{|V_A|^2} \quad (1)$$

where  $V_A$  is the voltage of branch A; the total number of branches is  $n$ ;  $P_A$ ,  $R_A$ , and  $Q_A$  are true power, resistance of the branch, and wattless power.

### 2.1. Algorithm of adopted method

ARO was used to choose the optimum reconfiguration. The optimum reconfiguration meets all objectives while incurring the fewest losses. On an IEEE 119 bus RDN, ARO is utilised to create an ideally reconfigured network with the fewest real power losses. Furthermore, by reducing losses, voltage levels are enhanced. ARO analyses rabbit behaviours [28].

Algorithm for the adopted ARO method

- Read the resistance, reactance, and bus load data from the IEEE 119 bus RDN.
- Set the ARO variables, the maximum iterations, and the population (tie switches) to their initial settings.
- Develop an arbitrary population of tie switches. Within the switches that are accessible for the IEEE 119 bus RDN, the method arbitrarily selects any switches that will serve as tie switches.
- Change the system's configuration.
- Verify if the network has been reconfigured and is radial. If so, calculate fitness (power losses) and select the elite candidate with the lowest losses. Go to step 4 if not.
- Determine the rabbit energy  $E$  using (7). If  $E > 1$ , perform the exploration phase given by (2)-(6) and update the position of tie switches, or else perform the exploitation phase given by (8)-(12) and update the position of tie switches.
- After the positioning details of all rabbits (tie switches) have been updated, measure their fitness (losses).

- h. Replace the elite if the level of fitness (loss) evaluation is lower.
- i. Print the elite (optimal reconfiguration) if the specified iterations have been completed.

### 3. ARTIFICIAL RABBITS OPTIMIZATION

ARO has been applied to choose the best reconfiguration. The best reconfiguration is the one that achieves all objectives while producing the fewest losses. ARO is used on an IEEE 119 bus RDN for obtaining an optimally reconfigured network with the least true power losses. Additionally, by diminishing the losses, the voltage levels are improved. ARO works by analyzing rabbit behaviors [28]. The phases below explain how the ARO approach searches.

#### 3.1. Detour foraging (exploration)

During foraging, the rabbit chooses to randomly travel to distant locations in search of food, without considering the surrounding environment. It is known as detour foraging, and (2) to (6) show the numerical formulation for it:

$$X_i(t+1) = X_j(t) + A \times (X_i(t) - X_j(t) + \text{round}(0.5 \times R_1)) \times n_1 \quad (2)$$

$$A = L \times c \quad (3)$$

$$L = \left( e - e^{\left(\frac{t-1}{T}\right)^2} \right) \times \sin(2\pi R_2) \quad (4)$$

$$g = \text{randperm}(D) \quad (5)$$

$$n_1 \sim N(0,1) \quad (6)$$

where:  $X_i(t+1) \rightarrow$  Candidate position of the  $i^{\text{th}}$  rabbit in iteration  $t+1$   
 $X_i(t) \rightarrow$  Position of  $i^{\text{th}}$  rabbit in iteration  $t$ ;  $X_j(t) \rightarrow$  Position of  $j^{\text{th}}$  rabbit in iteration  $t$   
 $b(k) = \begin{cases} 1, & \text{if } k == g(l) \\ 0, & \text{otherwise} \end{cases} \quad k = 1, \dots, D \text{ and } l = 1, \dots, [R3 \times D]$   
 $L \rightarrow$  running length of the rabbits;  $N \rightarrow$  Denotes the population size;  $D$  is Dimension size  
 $T \rightarrow$  Maximum number of iterations

The numbers  $R_1$ ,  $R_2$ ,  $R_3$ , and  $R_4$  are all arbitrary inside the interval  $[0, 1]$ .

#### 3.2. Exploration to exploitation changeover

During ARO, rabbits frequently participate in random concealment in the latter parts of the hunt, whereas they are more inclined to be involved in persistent detour foraging in the beginning phases of the process. In (7) provides an example of how to use the energy of the rabbit to create a balanced ratio of exploitation to exploration.

$$E(t) = 4 \left( 1 - \frac{t}{T} \right) \ln \frac{1}{R_4} \quad (7)$$

#### 3.3. Random hiding (exploitation)

Predators commonly pursue and harm rabbits. In ARO, a rabbit regularly builds  $D$  passages spanning the dimensions of the search region before choosing one at random for concealment in to reduce the danger of being identified. In (8) to (12) provide a mathematical rationale for this behaviour:

$$X_i(t+1) = X_i(t) + A \times (R_5 \times b_{i,r}(t) - X_i(t)) \quad (8)$$

$$b_{i,r}(t) = X_i(t) + H \times g_r(k) \times X_i(t) \quad (9)$$

$$g_r(k) = \begin{cases} 1, & \text{if } k == [R_6 \times D] \\ 0, & \text{otherwise} \end{cases} \quad (10)$$

$$H = \frac{T-t+1}{T} \times n_2 \quad (11)$$

$$n_2 \sim N(0,1) \quad (12)$$

$b_{i,r}(t)$  depicts the  $i$ th rabbit's burrow at random from  $D$  burrows.  $R_5$  and  $R_6$  are two random numbers between 0 and 1, and  $n_2$  follows the normal distribution.

#### 4. RESULTS AND DISCUSSION

ARO was used to choose the optimum reconfiguration. The optimum reconfiguration meets all objectives while incurring the fewest losses. On an IEEE 119 bus RDN, ARO is utilized to create an ideally reconfigured network with the fewest real power losses.

##### 4.1. IEEE 119 bus RDN

The conventional IEEE 119 bus RDN is depicted in Figure 1. The true power loss and voltage for the base setup are 1296.57 kW and 0.8688 pu. The ideal reconfiguration that would diminish losses and improve the voltage characteristics is found using the ARO approach. After forming a population (tie switches) at random, the RDN is reconfigured. The chosen approach only provides acceptable configurations that adhere to the bounds and ignores all other configurations. Each reconfigured network's losses are evaluated, and the best choice is the one with the lowest losses.




Figure 1. IEEE 119 bus RDN

Table 1 exhibits the findings for the IEEE 119 bus RDN. Table 1 demonstrates that the operation of the tie-switches 23, 43, 120, 51, 122, 61, 39, 95, 71, 74, 97, 129, 130, 109, and 132 is the ideal reconfigured network accomplished by the proposed technique. Real power losses on the 119-bus system were reduced by the adopted technique from 1296.57 kW for the 119-bus RDN's basic configuration to 851.01 kW. Comparing this ideal arrangement to the other possible configurations, the best configuration has the lowest

losses, at 851.01 kW. Comparing the suggested approach to existing ones, the per-unit voltage magnitude increased to 0.9412.

Table 1. Outcomes for IEEE 119 bus RDN

| Method              | Tie switches  | Real power loss (kW) | Loss mitigation (%) | Minimal voltage (pu) | CPU time (secs) |
|---------------------|---|----------------------|---------------------|----------------------|-----------------|
| Base configuration  | 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, and 132 | 1296.57              | NA                  | 0.8688               | NA              |
| SSOE [7]            | 23, 25, 34, 39, 42, 50, 58, 71, 74, 95, 97, 109, 121, 129, and 130            | 853.6                | 34.16               | 0.9323               | 4.03            |
| MSSOE [8]           | 23, 26, 34, 39, 42, 50, 58, 71, 74, 95, 97, 109, 121, 129, and 130            | 854.03               | 34.13               | 0.9323               | 2.52            |
| CGA-ISP [10]        | 23, 25, 34, 39, 42, 50, 58, 71, 74, 95, 97, 109, 121, 129, and 130            | 855.04               | 34                  | 0.929                | 32.28           |
| Adopted Methodology | 23, 43, 120, 51, 122, 61, 39, 95, 71, 74, 97, 129, 130, 109, and 132          | 851.01               | 34.36               | 0.9412               | 2.41            |

Figures 2 and 3 illustrate true power loss and the minimum voltage comparison for a IEEE 119 bus RDN. In comparison to the reconfiguration of the IEEE 119 bus RDN utilising the present methods, Figure 2 demonstrates that the adopted method produced the lowest losses. Figure 3 gives the comparison of minimum voltage pu values for the adopted methodology and existing methods. The minimum voltage for the base configuration is 0.8688 pu. Besides decreasing the losses, the optimal reconfigured network obtained by the adopted methodology has also enhanced the minimum voltage pu value to 0.9412, which is better than the existing methods. Figure 4 depicts the comparison of node voltages post-reconfiguration for an IEEE 119 bus RDN. From the figure, it could be noticed that the implementation of the adopted method on IEEE 119 bus RDN has shown better voltage levels as compared to previous approaches.




Figure 2. True power loss comparison




Figure 3. Comparison of minimum voltage

#### 4.2. IEEE 119 Bus RDN at various load levels

The following load levels are examined in order to determine the effectiveness of the adopted method. Scenario 1: light load situation with a 0.5 pu loading. Scenario 2: a normal load state of 1.0 pu. Scenario 3: 1.6 pu load (heavy load situation).

The loading status of the IEEE 119 bus RDN under consideration is considered to be light, with a 50% reduction from the typical load. The above system is classified as a normal load while the initial load remains constant. The load on the system rises to 160% of its normal load level, indicating a significant load.

Table 2 displays the results achieved by applying the accepted approach for the IEEE 119 bus RDN under light, normal, and heavy load situations. The true power losses and minimal voltage values of an IEEE 119 bus RDN are compared. The table shows that real power losses are higher when the IEEE 119 bus RDN is highly loaded compared to normal and moderate load situations. When compared to normal and light load situations, the minimum voltage is lower with a high load.




Figure 4. Comparison of node voltages post-reconfiguration

Table 2. Outcomes for IEEE 119 bus RDN at light, normal and heavy loads

| Parameter               | Base case<br>(light load)  | Adopted method<br>(light load)   | Base case<br>(normal load)   | Adopted method<br>(normal load)   | Base case<br>(heavy load)  | Adopted method<br>(heavy load)   |
|-------------------------|--|--|--|---|--|--|
| Tie switches            | 118, 119, 120,<br>121, 122, 123,<br>124, 125, 126,<br>127, 128, 129,<br>130, 131, and<br>132 | 23, 43, 120, 51,<br>122, 61, 39, 95,<br>71, 74, 97, 129,<br>130, 109, and<br>132 | 118, 119, 120,<br>121, 122, 123,<br>124, 125, 126,<br>127, 128, 129,<br>130, 131, and<br>132 | 23, 43, 120, 51,<br>122, 61, 39, 95, 71,<br>74, 97, 129, 130,<br>109, and 132 | 118, 119, 120,<br>121, 122, 123,<br>124, 125, 126,<br>127, 128, 129,<br>130, 131, and<br>132 | 23, 43, 120, 51,<br>122, 61, 39, 95,<br>71, 74, 97, 129,<br>130, 109, and<br>132 |
| Real power<br>loss (kW) | 324.14   | 252.75   | 1296.57  | 851.01  | 3630.39  | 2297.72  |
| Loss<br>mitigation (%)  | NA   | 22.02  | NA   | 34.36   | NA   | 36.71  |
| Minimal<br>voltage (pu) | 0.8981   | 0.9642   | 0.8688   | 0.9412  | 0.8271   | 0.9123   |

Figures 5 and 6 show the comparison of true power loss and minimum voltage levels for an IEEE 119 bus RDN at various load conditions with adopted method. When the IEEE119 bus RDN is heavily loaded, actual power losses are greater than in normal and light load conditions. When compared to normal and light load conditions, the lowest voltage with a high load is lower.




Figure 5. True power loss comparison




Figure 6. Comparison of minimum voltage

## 5. CONCLUSION

In this study, a novel technique called ARO is presented to decrease losses while raising voltage in RDN. By using ARO, the ideal reconfiguration is accomplished. IEEE 119 bus RDN is used to evaluate the accomplishment of the adopted method for minimising loss and improving voltage profiles under light, normal, and heavy load conditions. When contrasted to current methods, the implemented methodology has produced superior outcomes regarding loss reduction, a better voltage profile, and reduced computational

time. This study will eventually be broadened by looking at the reconfiguration under other hybrid algorithms and network topologies.

## REFERENCES




- [1] E. Guanochanga, A. Águila, and L. Ortiz, "Multicriteria analysis for optimal reconfiguration of a distribution network in case of failures," *Heliyon*, vol. 9, no. 3, p. e13723, Mar. 2023, doi: 10.1016/j.heliyon.2023.e13723.
- [2] D. Otuo-Acheampong, G. I. Rashed, A. M. Akwasi, and H. Haider, "Application of optimal network reconfiguration for loss minimization and voltage profile enhancement of distribution system using heap-based optimizer," *International Transactions on Electrical Energy Systems*, vol. 2023, pp. 1–17, Apr. 2023, doi: 10.1155/2023/9930954.
- [3] T. H. B. Huy, "Enhancing distribution system performance via distributed generation placement and reconfiguration based on improved symbiotic organisms search," *Journal of Control Science and Engineering*, vol. 2023, pp. 1–10, Mar. 2023, doi: 10.1155/2023/6081991.
- [4] S. S. Parihar and N. Malik, "Network reconfiguration in the presence of optimally integrated multiple distributed generation units in a radial distribution network," *Engineering Optimization*, vol. 56, no. 5, pp. 679–699, 2024, doi: 10.1080/0305215X.2023.2187790.
- [5] G. P. Rao and P. R. Babu, "Load balancing and restoring service using hybrid ant lion and improved mayfly optimization technique," *Journal of Asian Energy Studies*, vol. 7, pp. 62–76, Apr. 2023, doi: 10.24112/jaes.070005.
- [6] J. D. Santos, F. Marques, L. P. G. Negrete, G. A. A. Brigatto, J. M. López-Lezama, and N. Muñoz-Galeano, "A novel solution method for the distribution network reconfiguration problem based on a search mechanism enhancement of the improved harmony search algorithm," *Energies*, vol. 15, no. 6, p. 2083, Mar. 2022, doi: 10.3390/en15062083.
- [7] J. Zhan, W. Liu, C. Y. Chung, and J. Yang, "Switch opening and exchange method for stochastic distribution network reconfiguration," *IEEE Transactions on Smart Grid*, vol. 11, no. 4, pp. 2995–3007, Jul. 2020, doi: 10.1109/TSG.2020.2974922.
- [8] V. Vai, S. Suk, R. Lorm, C. Chhlonh, S. Eng, and L. Bun, "Optimal reconfiguration in distribution systems with distributed generations based on modified sequential switch opening and exchange," *Applied Sciences (Switzerland)*, vol. 11, no. 5, pp. 1–14, Feb. 2021, doi: 10.3390/app11052146.
- [9] T. Tran The, D. Vo Ngoc, and N. T. Anh, "Distribution network reconfiguration for power loss reduction and voltage profile improvement using chaotic stochastic fractal search algorithm," *Complexity*, vol. 2020, pp. 1–15, Mar. 2020, doi: 10.1155/2020/2353901.
- [10] T. T. Nguyen, T. T. Nguyen, and N. A. Nguyen, "Optimal network reconfiguration to reduce power loss using an initial searching point for continuous genetic algorithm," *Complexity*, vol. 2020, pp. 1–21, May 2020, doi: 10.1155/2020/2420171.
- [11] M. Ayalew, B. Khan, and Z. M. Alaas, "Optimal service restoration scheme for radial distribution network using teaching learning based optimization," *Energies*, vol. 15, no. 7, p. 2505, Mar. 2022, doi: 10.3390/en15072505.
- [12] J. Wen, X. Qu, L. Jiang, and S. Lin, "A hierarchical restoration mechanism for distribution networks considering multiple faults," *Mathematical Problems in Engineering*, vol. 2022, pp. 1–17, Jan. 2022, doi: 10.1155/2022/8787262.
- [13] S. A. Ahmadi, V. Vahidinasab, M. S. Ghazizadeh, and D. Giaouris, "A stochastic framework for secure reconfiguration of active distribution networks," *IET Generation, Transmission and Distribution*, vol. 16, no. 3, pp. 580–590, Feb. 2022, doi: 10.1049/gtd2.12303.
- [14] S. A. Kumar, S. Padma, and S. Madhubalan, "Distribution network reconfiguration using hybrid optimization technique," *Intelligent Automation and Soft Computing*, vol. 33, no. 2, pp. 777–789, 2022, doi: 10.32604/iasc.2022.023702.
- [15] M. Ntombela and M. Kabeya, "Reduction of power losses and voltage profile improvement in a smart grid incorporated with electric vehicles," *Sustainability (Switzerland)*, vol. 15, no. 13, p. 10132, Jun. 2023, doi: 10.3390/su151310132.
- [16] K. S. Sambaiah and T. Jayabarathi, "Optimal reconfiguration and renewable distributed generation allocation in electric distribution systems," *International Journal of Ambient Energy*, vol. 42, no. 9, pp. 1018–1031, Jul. 2021, doi: 10.1080/01430750.2019.1583604.
- [17] A. P. Hota, S. Mishra, D. P. Mishra, and S. R. Salkuti, "Allocating active power loss with network reconfiguration in electrical power distribution systems," *International Journal of Power Electronics and Drive Systems*, vol. 12, no. 1, pp. 130–138, Mar. 2021, doi: 10.11591/ijpeds.v12.i1.pp130-138.
- [18] G. P. Rao and P. R. Babu, "Network reconfiguration and optimal allocation of multiple DG units in radial distribution system," *International Journal of Advanced Technology and Engineering Exploration*, vol. 8, no. 81, pp. 1019–1032, Aug. 2021, doi: 10.19101/IJATEE.2021.874104.
- [19] M. Al Samman, H. Mokhlis, N. N. Mansor, H. Mohamad, H. Suyono, and N. M. Sapari, "Fast optimal network reconfiguration with guided initialization based on a simplified network approach," *IEEE Access*, vol. 8, pp. 11948–11963, 2020, doi: 10.1109/ACCESS.2020.2964848.
- [20] O. M. Neda, "A new hybrid algorithm for solving distribution network reconfiguration under different load conditions," *Indonesian Journal of Electrical Engineering and Computer Science*, vol. 20, no. 3, pp. 1118–1127, Dec. 2020, doi: 10.11591/ijeecs.v20.i3.pp1118-1127.
- [21] S. Essallah and A. Khedher, "Optimization of distribution system operation by network reconfiguration and DG integration using MPSO algorithm," *Renewable Energy Focus*, vol. 34, pp. 37–46, Sep. 2020, doi: 10.1016/j.ref.2020.04.002.
- [22] K. S. Sambaiah and T. Jayabarathi, "Loss minimization techniques for optimal operation and planning of distribution systems: a review of different methodologies," *International Transactions on Electrical Energy Systems*, vol. 30, no. 2, Feb. 2020, doi: 10.1002/2050-7038.12230.
- [23] J. Zhu, Y. Yuan, and W. Wang, "An exact microgrid formation model for load restoration in resilient distribution system," *International Journal of Electrical Power and Energy Systems*, vol. 116, p. 105568, Mar. 2020, doi: 10.1016/j.ijepes.2019.105568.
- [24] H. F. Kadom, A. N. Hussain, and W. K. S. Al-Jubori, "Dual technique of reconfiguration and capacitor placement for distribution system," *International Journal of Electrical and Computer Engineering*, vol. 10, no. 1, pp. 80–90, Feb. 2020, doi: 10.11591/ijece.v10i1.pp80-90.
- [25] P. K. Roy and S. Sultana, "Optimal reconfiguration of capacitor based radial distribution system using chaotic quasi oppositional chemical reaction optimization," *Microsystem Technologies*, vol. 28, no. 2, pp. 499–511, Feb. 2020, doi: 10.1007/s00542-020-04885-8.






- [26] J. Wang, W. Wang, Z. Yuan, H. Wang, and J. Wu, "A chaos disturbed beetle antennae search algorithm for a multiobjective distribution network reconfiguration considering the variation of load and dg," *IEEE Access*, vol. 8, pp. 97392–97407, 2020, doi: 10.1109/ACCESS.2020.2997378.
- [27] Y. Wang, Y. Xu, J. Li, J. He, and X. Wang, "On the radiality constraints for distribution system restoration and reconfiguration problems," *IEEE Transactions on Power Systems*, vol. 35, no. 4, pp. 3294–3296, Jul. 2020, doi: 10.1109/TPWRS.2020.2991356.
- [28] L. Wang, Q. Cao, Z. Zhang, S. Mirjalili, and W. Zhao, "Artificial rabbits optimization: A new bio-inspired meta-heuristic algorithm for solving engineering optimization problems," *Engineering Applications of Artificial Intelligence*, vol. 114, p. 105082, Sep. 2022, doi: 10.1016/j.engappai.2022.105082.

## BIOGRAPHIES OF AUTHORS






**Ganney Poorna Chandra Rao**    is an associate professor in the Department of Electrical and Electronics Engineering at Vignana Bharathi Institute of Technology. He earned a B.Tech. from Chittoor's Sreenivasa Institute of Technology and Management Studies. He earned an M.Tech. from the Sreenidhi Institute of Science and Technology in Hyderabad. He has completed his Ph.D. in electrical and electronics engineering at Visvesvaraya Technological University in Belagavi. He has 16 years of professional teaching experience and 15 articles in peer-reviewed journals. He can be contacted at email: g.poornachandrarao@gmail.com.






**Puvvula Venkata Rama Krishna**    is an associate professor at GITAM (deemed to be a university), Hyderabad, Department of Electrical and Electronics Engineering. In 2020, he obtained his Ph.D. from JNTU in Hyderabad. He earned a B.E. in EEE from the Osmania University of Hyderabad in Telangana in 2000 and an M.Tech. in power systems from IIT-Roorkee in 2004. He has been teaching for 19 years. He is supervising 5 Ph.D. students at GITAM (deemed to be university), Hyderabad. He can be contacted at email: rpuvvula@gitam.edu.







**Mailugundla Rupesh**    earned a B.Tech. in Electrical and Electronics Engineering from BV Raju Institute of Technology in Narsapur, Andhra Pradesh, in 2010 and an M.Tech. in Power System Control and Automation from Jayamukhi Institute of Technological Sciences in Narsampet, Andhra Pradesh, in 2013. He has completed his Ph.D. from Visvesvaraya Technological University in Belagavi, Karnataka, India. He has ten years of teaching experience. Since 2017, he has been working as an assistant professor in the Department of Electrical and Electronics Engineering at the BVRIT HYDERABAD College of Engineering for Women in Hyderabad, Telangana, India. He can be contacted at email: m.rupesh1@gmail.com.







**Swathi Karike**    is an associate professor in the Department of Electrical and Electronics Engineering at Nalla Narasimha Reddy Education Society's Group of Institutions. She received her B.Tech. degree in Electrical and Electronics Engineering from JNTU Hyderabad in 2008, her M.Tech. degree from JNTU Hyderabad in 2012, and is currently pursuing a Ph.D. from Koneru Lakshmaiah Education Foundation, Vaddeswaram, Guntur. Her areas of interest are the application of optimisation in power electronics, and electrical vehicles. She can be contacted at email: swathikarikephd@gmail.com.









**Sathyanarayana Polisetty**     is an assistant professor in the electrical and electronics engineering department at the Sreenidhi Institute of Science and Technology, Hyderabad, in Telangana. He received a B.E. in Electrical and Electronics Engineering from Vasavi College of Engineering in Hyderabad and an M.Tech. in Embedded Systems from Jawaharlal Nehru Technological University in Hyderabad. He is currently pursuing a Ph.D. from GITAM (deemed to be university) in Visakhapatnam, Andhra Pradesh. He can be contacted at email: satya.polisetty@gmail.com.



**Sareddy Venkata Rami Reddy**     received his B.Tech. degree from KSRRM College of Engineering, Kadapa, in 2007. He received his M.Tech. degree from SITS College of Engineering, Kadapa, in 2015. He is now pursuing his Ph.D. degree from the Vels Institute of Science, Technology and Advanced Studies, Chennai. He is currently working as an assistant professor in the Department of Electrical and Electronics Engineering at Jawaharlal Nehru Technological University Anantapur College of Engineering, Pulivendula. He has 9 years of teaching experience and 2 years of industrial work experience. He has published more than 10 papers in UGC, SCOPUS, and SCI. He has published three Indian patents. He can be contacted at email: svrami@gmail.com.



**Jadapalli Sreedhar**     is an Associate Professor in the Department of Electrical and Electronics Engineering at Vignana Bharathi Institute of Technology. He received his B.Tech. from Annamacharya Institute of Technology and Sciences. He received his M.Tech. from the Rajeev Gandhi Memorial College of Engineering and Technology in Nandyal. He received his Ph.D. from GITAM University, Hyderabad. He has 20 years of professional teaching experience and 25 articles published in peer-reviewed journals. He can be contacted at email: sreedharmtech@gmail.com.